

EXIT TERMINALS OF MECHANICAL DRAFT AND DIRECT-VENT VENTING SYSTEMS

DIRECT-VENT TERMINAL CLEARANCE
MINIMUM CLEARANCE, C

| INPUT (BTU/HR) | CLEARANCE (IN.) |
|------------------|-----------------|
| 10,000 OR LESS | 6 |
| 10,001 TO 50,000 | 9 |
| OVER 50,000 | 12 |

[SEE SECTION 503.8, ITEM 3]

MECHANICAL DRAFT VENT TERMINAL
[SEE SECTION 503.8, ITEM 2]

MECHANICAL DRAFT VENT TERMINAL
[SEE SECTION 503.8, ITEM 1]

FORCED-AIR INLET

Grade

APPENDIX C-C

EXIT TERMINALS OF MECHANICAL DRAFT AND DIRECT-VENT VENTING SYSTEMS

