

APPENDIX Q

ICC INTERNATIONAL RESIDENTIAL CODE ELECTRICAL PROVISIONS/NATIONAL ELECTRICAL CODE CROSS-REFERENCE (Not Adopted by the State of Oregon)

(This appendix is informative and is not part of the code. This table is a cross-reference of the *International Residential Code*, Chapters 34 through 43, and the 2008 *National Electrical Code*, NFPA 70).

International Residential Code	National Electrical Code
CHAPTER 34	GENERAL REQUIREMENTS
SECTION E3401	GENERAL
E3401.1	Applicability None
E3401.2	Scope 90.2
E3401.3	Not covered 90.2
E3401.4	Additions and alterations None
SECTION E3402	BUILDING STRUCTURE PROTECTION
E3402.1	Drilling and notching None
E3402.2	Penetrations of fire-resistance-rated assemblies 300.21
E3402.3	Penetrations of firestops and draftstops 300.21
SECTION E3403	INSPECTION AND APPROVAL
E3403.1	Approval 110.2
E3403.2	Inspection required None
E3403.3	Listing and labeling 110.3
SECTION E3404	GENERAL EQUIPMENT REQUIREMENTS
E3404.1	Voltages 110.4
E3404.2	Interrupting rating 110.9
E3404.3	Circuit characteristics 110.10
E3404.4	Protection of equipment 110.11
E3404.5	Unused openings 110.12(A)
E3404.6	Integrity of electrical equipment 110.12(C)
E3404.7	Mounting 110.13(A)
E3404.8	Energized parts guarded against accidental contact 110.27(A)
E3404.9	Prevent physical damage 110.27(B)
E3404.10	Equipment identification 110.21
E3404.11	Identification of disconnecting means 110.22
SECTION E3405	EQUIPMENT LOCATION AND CLEARANCES
E3405.1	Working space and clearances 110.26
Figure E3405.1	Working space and clearances 110.26(A)
	Footnote 1 110.26(F)(1)(a)
	Footnote 2 110.26(A)(3) and 110.26(E)
	Footnote 3 110.26(B)
	Footnote 4 230.70(A), 240.24(D), (E), & (F), Footnote 5
	Footnote 5 110.26(D)
E3405.2	Working clearances for energized equipment and panelboards 110.26(A)(1), (2), & (3)
E3405.3	Clearances over panelboards 110.26(F)(1)(a)
E3405.4	Location of clear spaces 110.26(B), 230.70(A) and 240.24(D), (E) & (F)
E3405.5	Access and entrance to working space 110.26(C)(1)
E3405.6	Illumination 110.26(D)
E3405.7	Headroom 110.26(E)
SECTION E3406	ELECTRICAL CONDUCTORS AND CONNECTIONS
E3406.1	General Articles 110, 300 and 310

APPENDIX Q

E3406.2	Conductor material	110.5
E3406.3	Minimum size of conductors	310.5
E3406.4	Stranded conductors	310.3
E3406.5	Individual conductor insulation	310.2(A) and 310.8
E3406.6	Conductors in parallel	310.4
E3406.7	Conductors of the same circuit	300.3(B)
E3406.8	Aluminum and copper connections	110.14
E3406.9	Terminals	110.14(A)
E3406.10	Splices	110.14(B)
E3406.10.1	Continuity	300.13(A)
	Exception	300.13(A)
E3406.10.2	Device connections	250.148 and 300.13(B)
E3406.10.3	Length of conductor for splice or termination	300.14
E3406.11	Grounded conductor continuity	200.2(B)

SECTION E3407 CONDUCTOR IDENTIFICATION

E3407.1	Grounded conductors	200.6(A), 200.6(B) and 310.12(A)
E3407.2	Equipment grounding conductors	250.119 and 310.12(B)
E3407.3	Ungrounded conductors	310.12(C), 310.12(C), Exception and 200.7(C)(1) & (C)(2)
E3407.4	Identification of terminals	200.10
E3407.4.1	Device terminals	200.10(A)
E3407.4.2	Receptacles, plugs, and connectors	200.10(B)
E3407.5	Polarity of connections	200.11

CHAPTER 35 ELECTRICAL DEFINITIONS

SECTION 3501 GENERAL	Article 100, Definitions, 210.12(A)
-----------------------------	-------------------------------------

CHAPTER 36 SERVICES

SECTION E3601 GENERAL SERVICES

E3601.1	Scope	230.1
E3601.2	Number of services	230.2
E3601.3	One building or other structure not to be supplied through another	230.3
E3601.4	Other conductors in raceway or cable	230.7
E3601.5	Raceway seal	230.8
E3601.6	Service disconnect required	230.70
E3601.6.1	Marking of service equipment and disconnects	230.66 and 230.70(B)
E3601.6.2	Service disconnect location	230.70 and 230.72(C)
E3601.7	Maximum number of disconnects	230.71(A)

SECTION E3602 SERVICE SIZE AND RATING

E3602.1	Rating of ungrounded conductors	230.79(C) and (D)
E3602.2	Service load	220.82(A)
E3602.2.1	Services under 100 amperes	None
Table E3602.2	Minimum service load calculation	220.82 (B) and (C)
E3602.3	Rating of service disconnect	230.79 & 230.80
E3602.4	Voltage rating	220.82(a)

SECTION E3603 SERVICE, FEEDER AND GROUNDING ELECTRODE CONDUCTOR SIZING

E3603.1	Grounded and ungrounded service conductor size	310.15(B)(6)
Table E3603.1	Service conductor and grounding electrode conductor sizing	Table 310.15(B)(6) and Table 250.66
	Footnote 1	250.64(E)
	Footnote 2	250.64(B)
	Footnote 3	250.64(B)
	Footnote 4	250.66(A) and (B)
E3603.2	Ungrounded service conductors for accessory buildings and structures	230.79(D)
	Exception 1	230.42 and 230.79(A)
	Exception 2	230.42 and 230.79(B)

E3603.3	Overload protection	230.90
E3603.3.1	Ungrounded conductor	230.90(A)
	Exception	230.90(A), Exception No. 3
E3603.3.2	Not in grounded conductor	230.90(B)
E3603.3.3	Location	230.91
E3603.4	Grounding electrode conductor size	250.66
E3603.5	Temperature limitations	110.14(C)(1)
SECTION E3604	OVERHEAD SERVICE-DROP AND SERVICE CONDUCTOR INSTALLATION	
E3604.1	Clearances on buildings	230.9
Figure E3604.1	Clearances from building openings	230.9
E3604.2	Vertical clearances	230.24
E3604.2.1	Above roofs	230.24(A)
	Exception 1	230.24(A), Exception No. 1
	Exception 2	230.24(A), Exception No. 2
	Exception 3	230.24(A), Exception No. 3
	Exception 4	230.24(A), Exception No. 4
Figure E3604.2.1	Clearances from roofs	230.24
E3604.2.2	Vertical clearance from grade	230.24(B)
	Item 1	230.24(B)(1)
	Item 2	230.24(B)(2)
	Item 3	230.24(B)(4)
E3604.3	Point of attachment	230.26
E3604.4	Means of attachment	230.27
E3604.5	Service masts as supports	230.28
E3604.6	Supports over buildings	230.29
SECTION E3605	SERVICE-ENTRANCE CONDUCTORS	
E3605.1	Insulation of service-entrance conductors	230.41
	Exception 1	230.41, Exception
	Exception 2	230.41, Exception
E3605.2	Wiring methods for services	230.43
E3605.3	Spliced conductors	230.46
E3605.4	Protection against physical damage	230.49
E3605.5	Protection of service cables against damage	230.50(A)
E3605.6	Direct sunlight exposure	310.8(D)
E3605.7	Mounting supports	230.51
E3605.8	Raceways to drain	230.53
E3605.9	Overhead service locations	230.54
E3605.9.1	Rain-tight service head	230.54(A)
E3605.9.2	Service cable, service head or gooseneck	230.54(B)
E3605.9.3	Service head location	230.54(C)
	Exception	230.54(C), Exception
E3605.9.4	Separately bushed openings	230.54(E)
E3605.9.5	Drip loops	230.54(F)
E3605.9.6	Conductor arrangement	230.54(G)
E3605.9.7	Secured	230.54(D)
SECTION E3606	SERVICE EQUIPMENT—GENERAL	
E3606.1	Service equipment enclosures	230.62
E3606.2	Working space	110.26
E3606.3	Available short-circuit current	110.9
E3606.4	Marking	230.66
SECTION E3607	SYSTEM GROUNDING	
E3607.1	System service ground	250.20(B)(1) and 250.24(A)
E3607.2	Location of grounding electrode conductor connection	250.24(A)(1) and (A)(5)
E3607.3	Buildings or structures supplied by feeder(s) or branch circuit(s)	250.32(A)

	Exception	250.32(A), Exception
E3607.3.1	Equipment grounding conductor	250.32(B) and Table 250.122
E3607.3.2	Grounded conductor.	250.32(B) Exception
E3607.4	Grounding electrode conductor	250.24(D)
E3607.5	Main bonding jumper	250.24(B)
E3607.6	Common grounding electrode	250.58

SECTION E3608 GROUNDING ELECTRODE SYSTEM

E3608.1	Grounding electrode system.	250.50
E3608.1	Exception.	250.50 Exception
E3608.1.1	Metal underground water pipe	250.52(A)(1)
E3608.1.1.1	Installation	250.53(D) and 250.53(E)
E3608.1.2	Concrete-encased electrode.	250.50(A)(3)
E3608.1.3	Ground Rings.	250.52(A)(4), 250.53(F)
E3608.1.4	Rod and pipe electrodes.	250.52(A)(5)
E3608.1.4.1	Installation.	250.53(G)
E3608.1.5	Plate electrodes	250.52(A)(6) and 250.53(H)
E3608.1.6	Other listed electrodes	250.52(A)(6)
E3608.2	Bonding Jumper	250.53(C)
E3608.3	Rod, pipe and plate electrode requirements	250.53(A) (B) and (E)
E3608.4	Resistance of rod, pipe and plate electrodes	250.56
E3608.5	Aluminum Electrodes	250.52(B)(2)
E3608.6	Metal underground gas piping system	250.52(B)(1)

SECTION E3609 BONDING

E3609.1	General	250.90
E3609.2	Bonding of service equipment	250.92(A)
E3609.3	Bonding to other systems.	250.94
E3609.4	Method of bonding at the service.	250.92(B)
E3609.4.1	Grounded service conductor	250.92(B)(1)
E3609.4.2	Threaded connections	250.92(B)(2)
E3609.4.3	Threadless couplings and connectors	250.92(B)(3)
E3609.4.4	Other devices	250.92(B)(4)
E3609.5	Sizing bonding jumper on supply side of service and main bonding jumper	250.102(C)
E3609.6	Metal water piping bonding	250.104(A)
E3609.7	Bonding other metal piping	250.104(B)

SECTION E3610 GROUNDING ELECTRODE CONDUCTORS

E3610.1	Continuous	250.64(C) and (F)
E3610.2	Securing and protection against physical damage.	250.64(A) and (B)
E3610.3	Enclosures for grounding electrode conductors	250.64(E)

SECTION E3611 GROUNDING ELECTRODE CONDUCTOR CONNECTION TO GROUNDING ELECTRODES

E3611.1	Methods of grounding connection to electrodes.	250.70
E3611.2	Accessibility	250.68(A)
E3611.3	Effective grounding path	250.68(B)
E3611.4	Protection of ground clamps and fittings	250.10
E3611.5	Clean surfaces	250.12

CHAPTER 37 BRANCH CIRCUIT AND FEEDER REQUIREMENTS

SECTION E3701 GENERAL

E3701.1	Scope	None
E3701.2	Branch-circuit and feeder ampacity.	210.19(A) and 215.2(A)(1)
E3701.3	Selection of ampacity	310.15(A)(2)
E3701.4	Multioutlet branch circuits	210.19(A)(2)
E3701.5	Multiwire branch circuits.	210.4
E3701.5.1	Disconnecting means	210.4(B)

E3701.5.2	Grouping	210.4(D)
SECTION E3702	BRANCH CIRCUIT RATINGS	
E3702.1	Branch-circuit voltage limitations	210.6(A) and (B)
E3702.2	Branch-circuit ampere rating	210.3
E3702.3	Fifteen- and 20-ampere branch circuits	210.23(A)
E3702.4	Thirty-ampere branch circuits	210.23(B)
E3702.5	Branch circuits serving multiple loads or outlets	210.23(A)
E3702.6	Branch circuits serving a single motor	430.22(A)
E3702.7	Branch circuits serving motor-operated and combination loads	220.18(A)
E3702.8	Branch-circuit inductive lighting loads	220.18(B)
E3702.9	Branch-circuit load for ranges and cooking appliances	Table 220.55, Note 4
E3702.9.1	Minimum branch circuit for ranges	210.19(A)(3)
E3702.10	Branch circuits serving heating loads	422.13 and 424.3(A) & (B)
E3702.11	Branch circuits for air-conditioning and heat pump equipment	440.35, 440.4(B) and 440.62(A)
E3702.12	Branch circuits serving room air conditioners	440.62(A)
E3702.12.1	Where no other loads are supplied.	440.62(B)
E3702.12.2	Where lighting units or other appliances are also supplied	440.62(C)
E3702.13	Branch-circuit requirement—summary	210.24 and 210.25
Table E3702.13	Branch-circuit requirement—summary.	Table 210.24
SECTION E3703	REQUIRED BRANCH CIRCUITS	
E3703.1	Branch circuits for heating	422.12 and 422.12 Exception
E3703.2	Kitchen and dining area receptacles	210.52 (B)(1)
E3703.3	Laundry circuit	210.23(A) Exception and 210.11(C)(2)
E3703.4	Bathroom branch circuits.	210.11(C)(3)
E3703.5	Number of branch circuits	210.11(A)
E3703.6	Branch-circuit load proportioning	210.11(B)
SECTION E3704	FEEDER REQUIREMENTS	
E3704.1	Conductor size	Table 310.15(B)(6), Sections 215.2 (A)(3), (A)(4) and 220.10(A)
E3704.2	Feeder loads	220.12
Table E3704.2(1)	Feeder load calculation	Table 220.12, Table 220.42(C), Sections 220.14, 220.50, 220.51, 220.52, 220.53, 220.54, 220.55 and 220.60
Table E3704.2(2)	Demand loads for electric ranges, wall-mounted ovens, counter-mounted cooking units and other cooking appliances over 1 ³ / ₄ kVA rating	Table 220.55
E3704.3	Feeder neutral load	220.61
E3704.4	Lighting and general use receptacle load	220.14(J), Table 220.12
E3704.5	Ampacity and calculated loads	220.40
E3704.6	Equipment grounding conductor	215.6
SECTION E3705	CONDUCTOR SIZING AND OVERCURRENT PROTECTION	
E3705.1	General	310.15(A)
Table E3705.1	Allowable ampacities	Table 310.16
E3705.2	Correction factors for ambient temperatures	Table 310.16
Table E3705.2	Ambient temperature correction factors	Table 310.16, Correction factors
E3705.3	Adjustment factor for conductor proximity	310.15(B)(2)(a)
Table E3705.3	Conductor proximity adjustment factors	Table 310.15(B)(2)(a)
E3705.4	Temperature limitations	110.14(C)
E3705.4.1	Conductors rated 60°C.	110.14(C)(1)(a)
E3705.4.2	Conductors rated 75°C.	110.14(C)(1)(b)
E3705.4.3	Separately installed pressure connectors	110.14(C)(2)
E3705.4.4	Conductors of type NM cable	334.80 and 334.112
E3705.5	Overcurrent protection required	Table 310.15(B)(6), Sections 240.4, 240.21
E3705.5.1	Cords	240.5
E3705.5.2	Overcurrent devices of the next higher size	240.4(B)
E3705.5.3	Small conductors.	240.4(D)
E3705.5.4	Air conditioning and heat pump equipment	240.4(G)

APPENDIX Q

E3705.6 Fuses and fixed trip circuit breakers Section 240.6
E3705.7 Location of overcurrent devices in or on premises 240.24(A),(C),(D),(E),(F)
E3705.8 Ready access for occupants Section 240.24(B)
E3705.9 Enclosures for overcurrent devices Section 240.30 (A) and (B)

SECTION E3706 PANELBOARDS

E3706.1 Panelboard rating 408.30
E3706.2 Panelboard circuit identification 408.4
E3706.3 Panelboard overcurrent protection 408.36
E3706.4 Grounded conductor terminations 408.41
E3706.5 Back-fed devices 408.36(D)

CHAPTER 38 WIRING METHODS

SECTION E3801 GENERAL REQUIREMENTS

E3801.1 Scope Section 300.1
E3801.2 Allowable wiring methods Sections 110.8 and 300.3(A)
Table E3801.2 Allowable wiring methods None
E3801.3 Circuit conductors 300.3(B)
E3801.4 Wiring method applications Chapter 3 and Section 300.2
Table E3801.4 Allowable applications for wiring methods Chapter 3 and Section 300.2

SECTION E3802 ABOVE-GROUND INSTALLATION REQUIREMENTS

E3802.1 Installation and support requirements Chapter 3
Table E3802.1 General installation and support requirements for wiring methods Chapter 3
E3802.2 Cables in accessible attics 320.23 and 334.23
E3802.2.1 Across structural members 320.23(A) and 334.23
E3802.2.2 Cable installed through or parallel to framing members 320.23(B)
E3802.3 Exposed cable 320.15 and 334.15
E3802.3.1 Surface installation 334.15(A)
E3802.3.2 Protection from physical damage 334.15(B)
E3802.3.3 Locations exposed to direct sunlight 310.8(D)
E3802.4 In unfinished basements 334.15(C)
E3802.5 Bends 334.24 and 338.24
E3802.6 Raceways exposed to different temperatures Section 300.7(A)
E3802.7 Wet locations above grade 300.9

SECTION E3803 UNDERGROUND INSTALLATION REQUIREMENTS

E3803.1 Minimum cover requirements 300.5(A)
Table E3803.1 Minimum cover requirements, burial in inches Table 300.5
E3803.2 Warning ribbon 300.5(D)(3)
E3803.3 Protection from damage 300.5(D)
E3803.4 Splices and taps 300.5(E)
E3803.5 Backfill 300.5(F)
E3803.6 Raceway seals 300.5(G)
E3803.7 Bushing 300.5(H)
E3803.8 Single conductors 300.5(I)
E3803.9 Ground movement Section 300.5(J)
E3803.10 Wet locations 300.5(B)
E3803.11 Under buildings 300.5(C)

CHAPTER 39 POWER AND LIGHTING DISTRIBUTION

SECTION E3901 RECEPTACLE OUTLETS

E3901.1 General 210.50 and 210.52
E3901.2 General-use receptacle distribution 210.52(A)
E3901.2.1 Spacing 210.52(A)(2)
E3902.2.2 Wall space 210.52(A)(2)

E3901.2.3	Floor receptacles	210.52(3)
E3901.3	Small appliance receptacles	210.52(B)(1)
E3901.3.1	Other outlets prohibited	210.52(B)(2)
E3901.3.2	Limitations	210.52(B)(3)
E3901.4	Countertop receptacles	210.52(C)
E3901.4.1	Wall counter space	210.52(C)(1)
E3901.4.2	Island counter spaces	210.52(C)(2)
E3901.4.3	Peninsular counter space	210.52(C)(3)
E3901.4.4	Separate spaces	210.52(C)(4)
E3901.4.5	Receptacle outlet location	210.52(C)(5)
E3901.5	Appliance outlets	210.50(C)
E3901.6	Bathroom	210.52(D)
E3901.7	Outdoor outlets	210.52(E)
E3901.8	Laundry areas	210.52(F)
E3901.9	Basements and garages	210.52(G)
E3901.10	Hallways	210.52(H)
E3901.11	HVAC outlet	210.63
SECTION E3902	GROUND-FAULT AND ARC-FAULT CIRCUIT-INTERRUPTER PROTECTION	
E3902.1	Bathroom receptacles	210.8(A)(1)
E3902.2	Garage and accessory building receptacles	210.8(A)(2)
E3902.3	Outdoor receptacles	210.8(A)(3)
E3902.4	Crawl space receptacles	210.8(A)(4)
E3902.5	Unfinished basement receptacles	210.8(A)(5)
E3902.6	Kitchen receptacles	210.8(A)(6)
E3902.7	Laundry, utility and wet bar sink receptacles	210.8(A)(7)
E3902.8	Boathouse receptacles	210.8(A)(8)
E3902.9	Boat hoists	210.8(C)
E3902.10	Electrically heated floors	424.44(G)
E3902.11	Exempt receptacles	210.8(A)(2)
E3902.12	Bedroom outlets	210.12
SECTION E3903	LIGHTING OUTLETS	
E3903.1	General	210.70(A)
E3903.2	Habitable rooms	210.70(A)(1)
E3903.3	Additional locations	210.70(A)(2)
E3903.4	Storage or equipment spaces	210.70(A)(3)
SECTION E3904	GENERAL INSTALLATION REQUIREMENTS	
E3904.1	Electrical continuity of metal raceways and enclosures	300.10
E3904.2	Mechanical continuity—raceways and cables	300.12
E3904.3	Securing and supporting	300.11(A)
E3904.3.1	Prohibited means of support	300.11(C)
E3904.4	Raceways as means of support	300.11(B)
E3904.5	Raceway installations	300.18
E3904.6	Conduit and tubing fill	300.17 and Chapter 9, Table 1 and Annex C
Tables E3904.6(1)- E3904.6(10)	Maximum number of conductors in conduit or tubing	300.17 and Chapter 9, Table 1, Note 1
E3904.7	Air handling—stud cavity and joist spaces	Section 300.22(C), Exception
CHAPTER E3905	BOXES, CONDUIT BODIES, AND FITTINGS	
E3905.1	Box, conduit body or fitting—where required	300.15
E3905.1.1	Equipment	300.15(B)
E3905.1.2	Protection	300.15(C)
E3905.1.3	Integral enclosure	300.15(E)
E3905.1.4	Fitting	300.15(F)

APPENDIX Q

E3905.1.5	Buried conductors	300.15(G)
E3905.1.6	Luminaires	300.15(J)
E3905.1.7	Closed loop	300.15(M)
E3905.2	Metal boxes	314.4
E3905.3	Nonmetallic boxes	314.3
E3905.3.1	Nonmetallic-sheathed cable and nonmetallic boxes	314.17(C)
E3905.3.2	Securing to box	314.17(C)
E3905.3.3	Conductor rating	314.17(C)
E3905.4	Minimum depth of outlet boxes	314.24
E3905.5	Boxes enclosing flush-mounted devices	314.19
E3905.6	Boxes at luminaire (lighting fixture) outlets	314.27(A)
E3905.7	Maximum luminaire (fixture) weight	314.27(B)
E3905.8	Floor boxes	314.27(C)
E3905.9	Boxes at fan outlets	314.27(D)
E3905.10	Utilization equipment	314.27(E)
E3905.11	Conduit bodies, junction, pull and outlet boxes to be accessible	314.29
E3905.12	Damp or wet locations	314.15
E3905.13	Number of conductors in outlet, device, and junction boxes and conduit boxes	314.16
E3905.13.1	Box volume calculations	314.16(A)
Table E3905.13.1	Maximum number of conductors in metal boxes	Table 314.16
E3905.13.1.1	Standard boxes	314.16(A)(1)
E3905.13.1.2	Other boxes	314.16(A)(2)
E3905.13.2	Box fill calculations	314.16(B)
E3905.13.2.1	Conductor fill	314.16(B)(1) and Table 314.16
Table E3905.13.2.1	Volume allowance required per conductor	Table 314.16(B)
E3905.13.2.2	Clamp fill	314.16(B)(2)
E3905.13.2.3	Support fittings fill	314.16(B)(3)
E3905.13.2.4	Device or equipment fill	314.16(B)(4)
E3905.13.2.5	Equipment grounding conductor fill	314.16(B)(5)
E3905.13.3	Conduit bodies	314.16(C)(1)
E3905.13.3.1	Splices, taps or devices	314.16(C)(2)

SECTION E3906 INSTALLATION OF BOXES, CONDUIT BODIES AND FITTINGS

E3906.1	Conductors entering boxes, conduit bodies or fittings	314.17
E3906.1.1	Insulated fittings	300.4(G)
E3906.2	Openings	314.17(A)
E3906.3	Metal boxes, conduit bodies and fittings	314.17, 314.17(B)
E3906.4	Unused openings	110.12(A)
E3906.5	In wall or ceiling	314.20
E3906.6	Plaster, gypsum board and plasterboard	314.21
E3906.7	Exposed surface extensions	314.22
E3906.8	Supports	314.23
E3906.8.1	Surface mounting	314.23(A)
E3906.8.2	Structural mounting	314.23(B)
E3906.8.2.1	Nails	314.23(B)(1)
E3906.8.2.2	Braces	314.23(B)(2)
E3906.8.3	Mounting in finished surfaces	314.23(C)
E3906.8.4	Raceway supported enclosures without devices or fixtures	314.23(E)
E3906.8.5	Raceway supported enclosures with devices or fixtures	314.23(F)
E3906.8.6	Enclosures in concrete or masonry	314.23(G)
E3906.9	Covers and canopies	314.25
E3906.10	Metal covers and plates	314.25(A)
E3906.11	Exposed combustible finish	314.25(B)

SECTION E3907 CABINETS AND PANELBOARDS

E3907.1	Enclosures for switches or overcurrent devices	312.8
---------	--	-------

E3907.2	Damp or wet locations	312.2(A)
E3907.3	Position in wall	312.3
E3907.4	Repairing plaster, drywall and plasterboard	312.4
E3907.5	Unused openings	110.12(A), 408.7
E3907.6	Conductors entering cabinets	300.4(F) and 312.5(B)
E3907.7	Openings to be closed	312.5(A)
E3907.8	Cables	312.5(C)

SECTION E3908 GROUNDING

E3908.1	Metal enclosures	250.86
E3908.2	Equipment fastened in place or connected by permanent wiring methods (fixed)	250.110(1), (2), and (3)
E3908.3	Specific equipment fastened in place or connected by permanent wiring methods	250.112(J), (L), and (M)
E3908.4	Performance of fault current path	250.4(A)(5)
E3908.5	Earth as a grounding conductor	250.4(A)(5)
E3908.6	Load-side neutral	250.24(A)(5)
E3908.7	Load-side equipment	250.142 (B)
E3908.8	Types of equipment grounding conductors	250.118
E3908.8.1	Flexible metal conduit	250.118(5)
E3908.8.2	Liquid-tight flexible metal conduit	250.118(6)
E3908.8.3	Nonmetallic sheathed cable (Type NM)	334.108
E3908.9	Equipment fastened in place or connected by permanent wiring methods	250.134
E3908.10	Methods of equipment grounding	250 Part (VII)
E3908.11	Equipment grounding conductor installation	250.120
E3908.12	Equipment grounding conductor size	250.122(A) and (B)
Table E3908.12	Equipment grounding conductor sizing	Table 250.122
E3908.12.1	Multiple circuits	250.122(C)
E3908.13	Continuity and attachment of equipment grounding conductors to boxes	250.148
E3908.14	Connecting receptacle grounding terminal to box	250.146(A), (B), and (C)
E3908.15	Metal boxes	250.8, 250.148(C)
E3908.16	Nonmetallic boxes	250.148(D)
E3908.17	Clean surfaces	250.12
E3908.18	Bonding other enclosures	250.96(A)
E3908.19	Size of equipment bonding jumper on load side of service	250.102(D)
E3908.20	Installation—equipment bonding jumper	250.102(E)

SECTION E3909 FLEXIBLE CORDS

E3909.1	Where permitted	400.7 and 400.8
E3909.2	Loading and protection	240.4, 240.5(A), 240.5(B)(1), 400.5, and 400.13
Table E3909.2	Maximum ampere load for flexible cords	Table 400.5(A)
E3909.3	Splices	400.9
E3909.4	Attachment plugs	400.7(B)

CHAPTER 40 DEVICES AND LIGHTING FIXTURES**SECTION E4001 SWITCHES**

E4001.1	Rating and application of snap switches	404.14(A)
E4001.2	CO/ALR snap switches	404.14(C)
E4001.3	Indicating	404.7
E4001.4	Time switches and similar devices	404.5
E4001.5	Grounding of enclosures	404.12
E4001.6	Access	404.8(A)
E4001.7	Wet locations	404.4
E4001.8	Grounded conductors	404.2(B)
E4001.9	Switch connections	404.2(A)
E4001.10	Box mounted	404.10(B)
E4001.11	Snap switch faceplates	404.9(A)

E4001.11.1 Faceplate grounding 404.9(B)
 E4001.12 Dimmer switches 404.14(E)
 E4001.13 Multipole snap switches 404.8(C)

SECTION E4002 RECEPTACLES

E4002.1 Rating and type 406.2(A)(B)
 E4002.1.1 Single receptacle 210.21(B)(1)
 E4002.1.2 Two or more receptacles 210.21(B)(3)
 Table E4002.1.2 Receptacle ratings for various size multioutlet circuits Table 210.21(B)(3)
 E4002.2 Grounding type 406.3(A)
 E4002.3 CO/ALR receptacles 406.2(C)
 E4002.4 Faceplates 406.5(B)
 E4002.5 Position of receptacle faces 406.4(D), and 406.5
 E4002.6 Receptacles mounted in boxes 406.4(A), and 406.4(B)
 E4002.7 Receptacles mounted on covers 406.4(C)
 E4002.8 Damp locations 406.8(A)
 E4002.9 15- and 20-ampere receptacles in wet locations 406.8(B)(1)
 E4002.10 Other receptacles in wet locations 406.8(B)(2)
 E4002.11 Bathtub and shower space 406.8(C)
 E4002.12 Flush mounting with faceplate 406.8(E)
 E4002.13 Exposed terminals 406.4(F)
 E4002.14 Tamper-resistant receptacles 406.11

SECTION E4003 LUMINAIRES

E4003.1 Energized parts 410.5
 E4003.2 Luminaires near combustible material 410.11
 E4003.3 Exposed conductive parts 410.42(A)
 E4003.4 Screw-shell type 410.90
 E4003.5 Recessed incandescent luminaires 410.115(C)
 E4003.6 Thermal protection 410.130(E)(1)
 E4003.7 High-intensity discharge luminaires 410.130(F)
 E4003.8 Metal halide lamp containment 410.130(F)(5)
 E4003.9 Wet or damp locations 410.10(A)
 E4003.10 Lampholders in wet or damp locations 410.96
 E4003.11 Bathtub and shower area 410.10(D)
 E4003.12 Luminaires in clothes closets 410.2 & 410.16(A), (B), (C), and (D)
 Figure E4003.12 Closet storage space Figure 410.2
 E4003.13 Luminaire wiring—general 410.48
 E4003.13.1 Polarization of luminaires 410.50
 E4003.13.2 Luminaires as raceways 410.64

SECTION E4004 LUMINAIRE INSTALLATION

E4004.1 Outlet box covers 410.22
 E4004.2 Combustible material at outlet boxes 410.23
 E4004.3 Access 410.8
 E4004.4 Supports 410.30(A)
 E4004.5 Means of support 410.36(A)
 E4004.6 Exposed ballasts 410.136(A)
 E4004.7 Combustible low-density cellulose fiberboard 410.136(B)
 E4004.8 Recessed fixture clearance 410.116(A)(1),(A)(2)
 E4004.9 Recessed fixture installation 410.116(B)

SECTION E4005 TRACK LIGHTING

E4005.1 Installation 410.151(A) and (B)
 E4005.2 Fittings 410.151(A) and (D)
 E4005.3 Connected load 410.151(B)
 E4005.4 Prohibited locations 410.151(C)
 E4005.5 Fastening 410.154

E4005.6	Grounding	410.155(B)
---------	-----------------	------------

CHAPTER 41 APPLIANCE INSTALLATION

SECTION E4101 GENERAL

E4101.1	Scope	422.1 and 424.1
E4101.2	Installation	110.3(B) and 422.17
E4101.3	Flexible cords	422.16
Table E4101.3	Flexible cord length	422.16(B)(1), (2) and (4)
E4101.4	Overcurrent protection	422.11
E4101.4.1	Single nonmotor-operated appliance	422.11(E)
E4101.5	Disconnecting means	422.30, 422.35 and 424.19
Table E4101.5	Disconnecting means	422.31(A),(B), 422.34, 422.35, 424.19, 424.20 and 440.14
E4101.6	Support of ceiling-suspended paddle fans	422.18
E4101.7	Snow-melting and deicing equipment protection	210.8(A)(3) Exception and 426.28

CHAPTER 42 SWIMMING POOLS

SECTION E4201 GENERAL

E4201.1	Scope	Section 680.1
E4201.2	Definitions	680.2

SECTION E4202 WIRING METHODS FOR POOLS, SPAS, HOT TUBS AND HYDROMASSAGE BATH TUBS

E4202.1	General .. 680.7, 680.23(B), 680.21(A), 680.23(F), 680.25(A), 680.40, 680.42, 680.43 and 680.70
E4202.2	Flexible cords .. 680.7(A), (B), 680.22(B)(5), 680.23(B)(3), 680.42, and 680.43 Exception
E4202.3	Double insulated pool pumps .. 680.21(B)

SECTION E4203 EQUIPMENT LOCATION AND CLEARANCES

E4203.1	Receptacle outlets	680.22(A)(5)
E4203.1.1	Location	680.22(A)(1)
E4203.1.2	Where required	680.22.(A)(3)
E4203.1.3	GFCI protection	680.22(B)
E4203.1.4	Indoor locations	680.43(A) and (A)(1)
E4203.1.5	Indoor GFCI protection	680.43(A)(2)
E4203.2	Switching devices	680.22(D), 680.43(C), 680.72
E4203.3	Disconnecting means	680.12
E4203.4	Luminaires and ceiling fans	680.22(C)
E4203.4.1	Outdoor location	680.22(C)(1)
E4203.4.2	Indoor location	680.22(C)(2)
E4203.4.3	Existing lighting outlets and luminaires	680.22(C)(3)
E4203.4.4	Indoor spas and hot tubs	680.43(B)
E4203.4.5	GFCI protection in adjacent areas	680.22(C)(4)
4203.5	Other outlets	680.22(E)
E4203.6	Overhead conductor clearances	680.8
Table E4203.6	Overhead conductor clearances	Table 680.8
E4203.7	Underground wiring	680.10
Table E4203.7	Underground wiring	Table 680.10

SECTION E4204 BONDING

E4204.1	Performance	680.26(A)
E4204.2	Bonded parts	680.26(B), 680.26(E), 680.42(B) and 680.43(D)(4)
E4204.3	Pool water	680.26(C)
E4204.4	Bonding of outdoor hot tubs and spas	680.42 and 680.42(B)
E4204.5	Bonding of indoor hot tubs and spas	680.43 (D)
E4204.5.1	Methods	680.43(E)
E4204.5.2	Connections	680.26(B)

SECTION E4205 GROUNDING

E4205.1	Equipment to be grounded	680.6
E4205.2	Luminaires and related equipment	680.23(F)(2), 680.24(F)
E4205.3	Nonmetallic conduit	680.23(B)(2)(b)
E4205.4	Flexible cords	680.23(B)(3)
E4205.5	Motors	680.21(A)(1)
E4205.6	Feeders	680.25(B) and (B)(1)
E4205.6.1	Separate Buildings	680.25(B)(2)
E4205.7	Cord-connected equipment	Section 680.7
E4205.8	Other equipment	680.6 and Article 250 Parts V, VI, and VII

SECTION E4206 EQUIPMENT INSTALLATION

E4206.1	Transformers	680.23(A)(2)
E4206.2	Ground-fault circuit-interrupters	680.5
E4206.3	Wiring on load side of ground-fault circuit-interrupters and transformers	680.23(F)(3)
E4206.4	Underwater luminaires	680.23(A)(1),(A)(3) and (A)(7)
E4206.4.1	Maximum voltage	680.23(A)(4)
E4206.4.2	Luminaire location	680.23(A)(5) and (A)(6)
E4206.5	Wet-niche luminaires	680.23(B)(1), (B)(2), (B)(4) and (B)(5)
E4206.5.1	Servicing	680.23(B)(6)
E4206.6	Dry-niche luminaires	680.23(C)(1) and (C)(2)
E4206.7	No-niche luminaires	680.23(D)
E4206.8	Through-wall lighting assembly	680.23(E)
E4206.9	Junction boxes and enclosures for transformers or ground-fault circuit interrupters	680.24(A) through (E)
E4206.9.1	Junction boxes	680.24(A)(1) and (A)(2)
E4206.9.2	Other enclosures	680.24(B)(1) and (2)
E4206.9.3	Protection of junction boxes and enclosures	680.24(C)
E4206.9.4	Grounding terminals	680.24(D)
E4206.9.5	Strain relief	680.24(E)
E4206.10	Underwater audio equipment	680.27(A)
E4206.10.1	Speakers	680.27(A)(1)
E4206.10.2	Wiring methods	680.27(A)(2)
E4206.10.3	Forming shell and metal screen	680.27(A)(3)
E4206.11	Electrically operated pool covers	680.27(B)(1) and (B)(2)
E4206.12	Electric pool water heaters	680.9
E4206.13	Pool area heating	680.27(C)
E4206.13.1	Unit heaters	680.27(C)(1)
E4206.13.2	Permanently wired radiant heaters	680.27(C)(2)
E4206.13.3	Radiant heating cables prohibited	680.27(C)(3)

SECTION E4207 STORABLE SWIMMING POOLS

E4207.1	Pumps	680.31
E4207.2	Ground-fault circuit-interrupters required	680.32
E4207.3	Luminaires	680.33
E4207.3.1	Fifteen (15) volts or less	680.33(A)
E4207.3.2	Not over 150 volts	680.33(B)
E4207.4	Receptacle locations	680.34

SECTION E4208 SPAS AND HOT TUBS

E4208.1	Ground-fault circuit-interrupters	680.44(A) and (C)
E4208.2	Electric water heaters	680.9
E4208.3	Underwater audio equipment	680.43(G)
E4208.4	Emergency switch for spas and hot tubs	680.41

SECTION E4209 HYDROMASSAGE BATHTUBS

E4209.1	Ground-fault circuit-interrupters	680.71
E4209.2	Other electric equipment	680.72

E4209.3	Accessibility	680.73
E4209.4	Bonding	680.74
CHAPTER 43	CLASS 2 REMOTE CONTROL, SIGNALING, AND POWER-LIMITED CIRCUITS	
SECTION E4301	GENERAL	
E4301.1	Scope	725.1
E4301.2	Definitions	Article 100 and Section 725.2
SECTION E4302	POWER SOURCES	
E4302.1	Power sources for Class 2 circuits	725.121(A)
E4302.2	Interconnection of power sources	725.121(B)
SECTION E4303	WIRING METHODS	
E4303.1	Wiring methods on supply side of Class 2 power source	725.127
E4303.2	Wiring methods and materials on load side of the Class 2 power source	725.130, 725.154, 725.179, Table 725.154(G)
Table E4303.2	Cable uses and permitted substitutions	725.154 and Table 725.154(G)
E4303.2.1	Type CL2P cables	725.154(A) and 725.179(A)
E4303.2.2	Type CL2 Cables	725.179(C)
E4303.2.3	Type CL2X Cables	725.154(E)(4) and 725.179(D)
E4303.2.4	Marking	725.179(L)
SECTION E4304	INSTALLATION REQUIREMENTS	
E4304.1	Separation from other conductors	725.136(A), (B), (C), (D)
E4304.2	Other applications	725.136(J)
E4304.3	Class 2 circuits with communication circuits	725.139(D)
E4304.4	Class 2 cables with other circuit cables	725.139(E)(1) through (5)
E4304.5	Installation of conductors and cables	725.21, 725.24, 725.143, 300.11(B)(2)

