

EDITORIAL CHANGES – SECOND PRINTING

Page 22, 202: High-hazard Group H-3 list now reads . . . Oxidizers, Class 3, that are used or stored in normally closed containers or systems pressurized at least 15 pounds per square inch gauge (103 kPa)

Page 28, Section 308.6 is added to read . . . **308.6 Flaming food and beverage preparation.** The preparation of flaming foods or beverages in places of assembly and drinking or dining establishments shall be in accordance with Section 308.6.

308.6.1 Dispensing. Flammable or combustible liquids used in the preparation of flaming foods or beverages shall be dispensed from one of the following:

1. A 1-ounce (29.6 ml) container; or
2. A container not exceeding 1-quart (946.5 ml) capacity with a controlled pouring device that will limit the flow to a 1-ounce (29.6 ml) serving.

308.6.2 Containers not in use. Containers shall be secured to prevent spillage when not in use.

308.6.3 Serving of flaming food. The serving of flaming foods or beverages shall be done in a safe manner and shall not create high flames. The pouring, ladling or spooning of liquids is restricted to a maximum height of 8 inches (203 mm) above the receiving receptacle.

308.6.4 Location. Flaming foods or beverages shall be prepared only in the immediate vicinity of the table being served. They shall not be transported or carried while burning.

308.6.5 Fire protection. The person preparing the flaming foods or beverages shall have a wet cloth towel immediately available for use in smothering the flames in the event of an emergency.

Page 30, 313.1: Exception 2 now reads . . . Where allowed by Section 313 or 314.

Page 30, 313.2: line 4 now reads . . . buildings.

Page 57, 804.1.1: Exception 2 now reads . . . Trees shall be permitted within dwelling units in Group R-2 occupancies.

Page 57, 804.4: line 2 now reads . . . Such flame retardance...

Page 57, 805.1.2: Exception, last line now reads . . . with Section 803.4 of the *International Building Code*.

Page 57, 805.2: line 3 now reads . . . approved agency and pass Test 1 or 2, as described...

Page 58, 806.2: Class C now reads . . . Flame spread index 76-200

Page 78, 907.2.10.1: line 3 now reads . . . in Sections 907.2.10.1.1 through 907.2.10.1.3.

Page 99, Table 1004.1.2: Column 2, row 6 now reads . . . See Section 1004.7

Page 102, 1007.5: line 5 now reads . . . with Section 604 shall be installed in accordance with ASME...

Page 133, 1026.21: now reads . . . **Stairway floor number signs.** Existing stairs shall be marked in accordance with Section 1019.1.7.

Page 151, 1417.3: Exception deleted

Page 188, 2206.2.4: line 5 now reads . . . Section 3404.2.8 and shall comply with Sections 2206.2.4.1...

Page 195, 2209.5: line 3 now reads . . . with Sections 2209.5.1 through 2209.5.4.3.

Page 195, 2209.5.4.2: Item 1, line 3 now reads . . . 2209.5.4.2 for the combinations of maximum...

Page 196, Table 2209.5.4.1 is now . . . TABLE 2209.5.4.2

Page 196, Figure 2209.5.4.1 is now . . . FIGURE 2209.5.4.2

Page 200, 2211.8.2: last line now reads . . . with Section 2211.8.1.2.

Page 218, 2505.6: Item 1, line 2 now reads . . . requirements in Sections 2505.1 through 2505.5.

Page 224, 2701.3.3.8: line 3 now reads . . . immediate harm to persons or property, means of mitigating the dangerous effects of a release shall be provided.

Page 235, Table 2703.8.2: last line of Explosives Class now reads . . . Division 1.6

Page 262, 3204.3.1.1: Paragraph 2, line 3 now reads . . . limits established by law as the limits of districts in

Page 292, 3404.2.9.5.1: line 4 now reads . . . within the limits established by law as the limits of

Page 307, 3405.2.4: now reads . . . Class I, II and III liquids. Class I and II liquids or Class III liquids that are heated up to or above their flash points shall be transferred by one of the following methods:

Page 312, 3406.2.4.4: line 4 now reads . . . by law as the limits of districts in which such storage

Page 312, 3406.2.8: Item 2 now reads . . . The dispensing hose does not exceed 100 feet (30 480 mm) in length.

Page 318, 3406.5.4: last line now reads . . . through 3406.5.4.5.

Page 330, 3703.2.5: now reads . . . **3703.2.5 Weather protection for highly toxic liquids and solids — outdoor storage or use.** Where overhead weather protection is provided for outdoor storage or use of highly toxic liquids or solids, and the weather protection is attached to a building, the storage or use area shall either be equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1, or storage or use vessels shall be fire-resistance rated. Weather protection shall be provided in accordance with Section 2704.13 for storage and Section 2705.3.9 for use.

EDITORIAL CHANGES – THIRD PRINTING

Page 30, 313.1: exception 2 now reads . . . Where allowed by Section 314.

Page 147, TABLE 1304.1: row 11, column 2 now reads . . . Manufacturing, Processing and Handling of Combustible Particulate Solids.

Page 198, 2211.3.2: second line now reads . . . garages except in approved locations.

Page 223, 2701.3: last line now reads . . . Chapters 28 through 44.

Page 224, 2701.5: second paragraph, last line now reads . . . closure plan in accordance with Section 2701.6.3.

Page 225, 2701.6.2: last line now reads . . . ity closure plan in accordance with Section 2701.6.3.

Page 225, 2701.6.3: second line now reads . . . is required in accordance with Section 2701.5 to terminate . . .

Page 229, Table 2703.1.1(1): Column 3, row 2, second line now reads . . . H-2 or H-3

Page 229, TABLE 2703.1.1(1)—continued: footnote f now reads . . . Quantities shall not be limited in a building equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1.

Page 272, TABLE 3304.5.2(2): line 19, column 4 now reads . . . 680.

Page 318, 3406.5.4.5: subsection 1, line 2 now reads . . . been issued a permit to conduct mobile fueling.

Page 331, 3704.1.2: line 3 now reads . . . 2703.8.6 and the following requirements:

EDITORIAL CHANGES – FOURTH PRINTING

Page 20, 202: Residential Group R, R-3, line 4 now reads . . . two dwelling units as applicable in Section 101.2 of the *International Building Code*.

Page 86, 909.5.1: line 2 now reads . . . is the product of the smoke barrier gross area multiplied by

Page 101, 1007.1: Exception 3, line 5 now reads . . . in Section 1024.8.

Page 103, 1008.1.2: Exception 3, line 3 now reads . . . 1001.1.

Page 104, 1008.1.2: Exception 6, line 2 now reads . . . 1008.1.3.2.

Page 116, 1015.2: line 6 now reads . . . feet (122 m) for occupancies in Group F-1 or S-1.

Page 188, 2206.2.3: line 3 now reads . . .of Class I, II or IIIA liquid motor fuels except as provided by

Page 188, 2206.2.4: line 3 now reads . . .of Class I, II or IIIA liquid motor fuels are allowed to be in-

Page 188, 2206.2.6: line 4 now reads . . .motor fuels are allowed to be installed in buildings in special

Page 189, 2206.3: line 2 now reads . . . motor fuels shall be safeguarded from public access or unaut-

Page 293, 3404.2.9.5.1.6: line 7 now reads . . .3404.2.9.5.1.2 through 3404.2.9.5.1.5 assuming a